



The Standards Institution of Israel

This is to certify that:

**Equipment Under Test: 5 kW 30-42 VDC
ElectroChemical Generator (ECG)**

Model: G5.2

Manufactured by: GenCell Ltd.

Address: 7 Hatnufa St., Petah-Tiqva, 4951025 Israel

Tested: 12 & 14/2/2017.

Has been tested by SII and was found to comply with the requirements of the following standards:

- ❖ **EN 55011 Group 1 - Class B**
Industrial, scientific and medical equipment - Radio-frequency disturbance characteristics - Limits and methods of measurement (2009/ A1: 2010).
- ❖ **EN 61000-6-2:**
Electromagnetic Compatibility (EMC);
Part 6-2: Generic standards - Immunity for industrial equipment (2005/ AC: 2005).

Test results are detailed in **SII Test Report No.9712305620.**

Certificate no. **9712305620**

Date of issue: February 19, 2017

Eng. Yuri Rozenberg

Head of EMC Branch

